



## ADDENDUM

---

### GENERAL INSTRUCTIONS:

1. This addendum shall be attached to the plans and shall be brought to the attention of all concerned.
  2. Any additional costs shall be incorporated in the tender form.
  3. Receipt of this addendum shall be acknowledged on the tender form.
  4. The following amendments shall be incorporated in and form part of the contract same as if these had been written into the original plans.
- 

PROJECT:	<u>A&amp;W Restaurant - North Battleford, SK</u>	DATE:	<u>April 27, 2016</u>
PROJECT #:	<u>15-15</u>		
ADDENDUM #:	<u>2</u>		

### 1. Drawing S-2:

- Column Schedule:
  - o Revise C1 column to 127x127x6.4.

### 2. Drawing E-5.0:

- Detail 3:
  - o The data cabling for the menu boards shall be the responsibility of the Electrical Contractor. Provide FT6 rated Cat 5e wiring. Conduit in ceiling space is not required.

END OF ADDENDUM