

1. GENERAL

- 1.1 This clarification shall be incorporated into and shall form an integral part of the contract documents. A clarification is being issued for the benefit of the contractors as no further addenda can be issued at this time.
- 1.2 The tender submitted shall include all costs to the contract, including any changes as a result of this clarification.
- 1.3 Advise all parties, trades and sub-trades of items affecting the work and coordinate accordingly.
- 1.4 Acknowledge receipt of this clarification on the tender form

2. ARCHITECTURAL

- 2.1 Refer to drawing A.101 and to note indicating “FOR APPROX, TOTAL OF 270 SQ.M. ALLOW 27M3 OF COMPACTED GRANULAR FILL.” Quantities indicated in this note are incorrect. The building area is approximately 195 sq.m. A thickness of 600mm of compacted granular fill is required throughout resulting in a volume of 117 cubic meters. Bidders are hereby required to allow for a total of **120 cubic meters** of compacted granular fill for this project.
- 2.2 Exact quantities will be reviewed on site during construction and if a lesser amount is required, a change order will be prepared to adjust pricing as might be appropriate.

*******END OF CLARIFICATION #1*******