

1. GENERAL

- 1.1 This addendum shall be incorporated into and shall form an integral part of the contract documents.
- 1.2 The tender submitted shall include all costs to the contract, including any changes as a result of this addendum.
- 1.3 Advise all parties, trades and sub-trades of items affecting the work and coordinate accordingly.
- 1.4 Acknowledge receipt of this addendum on the tender form

2. ARCHITECTURAL

- 2.1 Refer to Specification Section 07610, Sheet Metal Roofing, Part 2 Products, Item 1.2, and revise to read as follows: Roof panels shall be 0.61mm (24 gauge) prefinished steel equivalent to Perspectra Plus Series (Agway Metals), QC #18307, Melchers Green or SMP Prepainted Steel, Melchers Green. Panels to be either 508mm or 406mm wide.
- 2.2 Refer to Specification Section 07610, Sheet Metal Roofing, Part 2 Products, Item 1.3, and revise to read as follows: Flashing shall be 0.61mm (24 gauge) prefinished metal, color and finish to match roof panels (Melchers Green).
- 2.3 Approved "equal" in Section 07610, Sheet Metal Roofing
 - 2.3.1 Specified: Prefinished 5000 Series. Melchers Green QC #8307.
Approved Equal: Knudson KR24 SS Panel, 1 ½" high with offsets cross-section. Color to be Melchers Green. Consultant would further advise as noted above, 406mm wide standing seam roofing panels are also acceptable.

*******END OF ADDENDUM #4*******